



2022 MRS[®] SPRING MEETING & EXHIBIT

May 8-13, 2022 | Honolulu, Hawai'i
May 23-25, 2022 | Virtual

Lithium Titanate Battery Durability and Reliability Under Electric Utility Grid Operations

Matthieu Dubarry & G. Baure

matthieu.dubarry@gmail.com



1680 East West Road, POST 109,
Honolulu, HI 96822
Ph: (808) 956-2349 • Fax: (808) 956-2336



Battery Durability and Reliability under Grid Operations

Integrate field data with lab testing to predict lifetime BESS


Objective/Significance

- Evaluate degradation & lifetime of BESS in support of grid scale deployment
- Improve economic understanding of future commercial & base deployments




Approach




- Assess battery performance in BESS and under controlled conditions
- Analyze degradation using non-destructive methods
- Link controlled and deployed degradation to forecast remaining useful life



Understand how the cells were utilized in the field




Custom design of experiment: Cover representative and aggressive usage




Battery Durability and Reliability under Electric Utility Grid Operations

Field data



O'ahu, HI (grid: 1.1TW)
1MW/250kWh,
Commissioned in February 2016
Altairnano GEN2 60Ah cells, 384(7P)S1P
Volt-VAR, Power quality

Moloka'i, HI (grid: 5.5MW)
2MW/330kWh, Commissioned in February 2016
Altairnano GEN2 60Ah cells, 416(7P)S1P
Reserve, Fault response




Big Island, HI (grid: 190MW)
1MW/250kWh, Commissioned in December 2012
Altairnano GEN1 50Ah cells, 384(7P)S1P
Frequency regulation, Wind Smoothing





Demonstrated over 8000 full cycles equivalent operation

Battery Durability and Reliability under Electric Utility Grid Operations

Laboratory testing – Cycle aging




Laboratory testing encompassing a wide range of grid applications including frequency regulation, reserve and peak shaving.




Battery Durability and Reliability under Electric Utility Grid Operations

Laboratory testing – Cycle aging



Laboratory testing – Cycle aging


No capacity loss do not mean no degradation...






Voltage variations differ in between cells: different degradations
Effect on remaining useful life?

Battery Durability and Reliability under Electric Utility Grid Operations

HNEI custom analysis: Incremental capacity analysis



Mechanistic modeling




'alawa

<https://www.soest.hawaii.edu/HNEI/alawa/>

Battery Durability and Reliability under Electric Utility Grid Operations

HNEI custom analysis: Incremental capacity analysis

Mechanistic modeling: Predict voltage response under different degradations




LLI: loss of lithium inventory

LAM: loss of active material

Assessed the impact of each active component of the cell

Battery Durability and Reliability under Electric Utility Grid Operations




HNEI custom analysis: Incremental capacity analysis



Impact of duty cycle on LAMs and LLI deciphered

Battery Durability and Reliability under Electric Utility Grid Operations


HNEI custom analysis: Incremental capacity analysis




Extrapolation of degradation modes enables prognosis

Battery Durability and Reliability under Electric Utility Grid Operations

HNEI custom analysis: Prognosis



Degradation mode quantification enables prognosis



Varied duty cycles showed degradation close to the ones of the main experiment

Battery Durability and Reliability under Electric Utility Grid Operations

Conclusions & Perspective

Cells tested **under conditions representative of the various grid usages**
Low capacity loss after more than 450 days of cycle-aging testing
20- year prognosis showed **possibility of accelerated aging** for some cells
Cells adapted for most grid usages

Perspective:

Model performance based on laboratory testing

Compare model to field data to determine BESS SOH (Electronics 2021, 10, 1593)

Optimize BESS control strategies to limit degradation

Acknowledgments

This work was supported by the Office of Naval Research (ONR)
Asia Pacific Research Initiative for Sustainable Energy Systems (APRISES),
award # N00014-17-1-2206.



Mahalo! Questions ?



matthieu@hawaii.edu

