



# Hawai'i Natural Energy Institute Research Highlights

## Grid Integration

### Energy Generation and Resilience Opportunities Assessment for MCBH

**OBJECTIVE AND SIGNIFICANCE:** HNEI has conducted an assessment of energy generation and resilience opportunities (“EG&R Assessment”) for Marine Corps Base Hawai‘i (MCBH) (Figure 1). This study seeks to identify and evaluate needs and opportunities for implementing cost-effective and commercially proven microgrid technologies (e.g., solar photovoltaics (PV), battery energy storage systems (BESS) and back-up diesel generation) on MCBH, while concurrently meeting MCBH’s 14-day resiliency requirement.



Figure 1. Aerial view of MCBH at Kaneohe Bay.

**BACKGROUND:** On May 30, 2018, the Office of the Assistant Secretary of Defense Energy, Installations, and Environment (OASD-EI&E) issued the memorandum, “Installation Energy Plans – Energy Resilience and Cybersecurity Update and Expansion of the Requirement to All DoD Installations,” mandating that an Installation Energy and Security Plan (IESP) be prepared for MCBH. HNEI was initially assisting MCBH with the development and completion of MCBH’s IESP and delivered a preliminary draft of the report in October 2020.

Earlier in 2020, the Marine Corps Installations Command (MCICOM) took over efforts to complete IESPs for all installations under its umbrella. As MCBH was still interested in HNEI’s assistance to identify base energy security gaps and evaluate alternative energy resilience solutions, the scope of work of HNEI’s analysis was updated and the EG&R Assessment was initiated.

**PROJECT STATUS/RESULTS:** After completing a preliminary analysis of the existing MCBH electrical infrastructure and loads in 2020, HNEI conducted a techno-economic analyses utilizing the proprietary

*XENDEE Microgrid Decision Support System*, evaluating optimized long-term hybrid microgrid solutions incorporating both existing and new on-base PV generation, BESS resources and back-up diesel generation.

Alternative microgrid designs have been proposed, developed and assessed, including microgrid solutions that range from powering the entire base (as illustrated by Figure 2), to smaller footprint microgrids that maintain power to each of the several base primary substations. Additionally, HNEI has analyzed the feasibility of microgrids at a more granular distribution feeder level – including at the request of MCBH leadership, an assessment of the potential for microgrid development cost reduction opportunities by the use of existing rooftop PV systems and emergency generation assets already in place at critical load centers on the base.




Figure 2. Conceptual design of a full-base microgrid.

HNEI delivered a draft EG&R Assessment report to MCBH in February 2022 that provided a technical and financial analysis to support the base’s command to make decisions on future projects considering the base’s grid modernization targets and resilience requirements. HNEI submitted its final version of the report to MCBH in July 2022.

*Funding Source:* Office of Naval Research

*Contact:* Leon Roose, [lroose@hawaii.edu](mailto:lroose@hawaii.edu)

*Last Updated:* May 2025